

Legend

- Monitoring Well and Designation
- Extraction Well and Designation
- Key Well and Designation
- Spring
- Treatment System Features
- NPBA Area
- TCA Area
- WPL Area
- Codorus Creek
- Buildings
- Harley Davidson Property Boundary
- Roads and Curb Boundary
- Railroad

NOTES: Five year average pumping rates were added to SAIC's original figure. Although records show the TCA tank area well (CW-8) yields to be 80 GPM, recent meter calibration indicates a 20% upward correction to be required, which was added to this map. The configuration of the toe drain portion of the Softail Dewatering System (see Section 4.2.8.1) was changed after construction of this map. It now extends further to the north.

N

NOTE:
1. Base data (Buildings, Building Boundaries, Roads and Curbs) from NuTec Survey conducted in 2006.

0 200 400 800
SCALE IN FEET

Harley-Davidson Motor Company Operations, Inc.

1425 Eden Rd York, Pa 17402

GROUNDWATER TREATMENT SYSTEM LOCATION

drawn AGM	checked	approved	figure no. 6.1-1
date 8/25/09	date	date	
job no. 4501020024		file no. Fig_1-2_Site_Plan_20100	

initials	date	revision

SAIC From Science to Solutions

K:\GIS_Data\Harley\Projects\2010 GW Ext TS Rpt\Fig_1-2_Site_Plan_20100208.mxd